

2012 Water Quality Report

Este informe contiene informacion muy importante sobre su agua de beber. Traduzcalo o hable con alguien que lo entienda bien. (This report contains very important information about your drinking water. Translate it, or speak to someone who understands it.)

We're pleased to present to you this year's Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our primary water source is a well field composed of eight vertical wells approximately 65 feet deep located near the Ohio River in Coraopolis. Although our wells tap the non-artesian aquifer found in the alluvial deposits of the Ohio River, the wells were determined not to be under the direct influence of the river. We purchase water from the Moon Township Municipal Authority (MTMA) to supply the higher elevations of the borough including Euclid Avenue and the top of Montour Street (above Grace Street), please refer to the MTMA report for more information.

We are pleased to report that our drinking water meets federal and state requirements.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

We have a source water assessment report available from our office that provides more detailed information such as potential sources of contamination. A summary of our water system's susceptibility to potential sources of contamination is as follows:

In 2003, the PA Department of Environmental Protection (PADEP) completed a Source Water Assessment of the aquifer, which supplies water to the Coraopolis Filtration Plant. The assessment has found that the aquifer is potentially most susceptible to contamination from transportation corridors, junk yards/scrap yards, combined sewer overflows, auto repair, machine shops, and former chemical disposal sites. Overall, the aquifer for Coraopolis is vulnerable to VOC (volatile organic compounds) contamination that requires our diligence. Summary reports of the Assessment are available at the Coraopolis Memorial Library and are also available on the PADEP website at <http://www.dep.state.pa.us/dep/deputate/watermgt/wc/Subjects/SrceProt/SourceAssessment/default.htm>. Complete reports were distributed to municipalities, water supplier, local planning agencies and PADEP offices. Copies of the complete report are available for review at the PA. DEP Southwest Regional Office, Records Management Unit at (412) 442-4000.

If you have any questions about this report or concerning your water utility, please contact **Richard Deems at 412-264-3003 between the hours 7 a.m. and 3 p.m.** We want our valued customers to be informed about their water utility. Effective January 2005 Borough Council gave the Coraopolis Water & Sewer Authority (CWSA) full operation and ownership of the water, sanitary sewage collection and storm systems. If you want to learn more, please attend any of our regularly scheduled authority meetings. They are held on the third Wednesday of each month at 6:30 pm at the Coraopolis Borough Municipal Building.

CWSA routinely monitors for constituents in your drinking water according to Federal and State laws. The table on the following pages shows the results of our monitoring for the period of January 1st to December 31st, 2012.

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/l) -

One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Action Level (AL) - The concentration of a contaminant, which if exceeded, triggers treatment or other requirements, which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water

below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Non-Detects (ND) - Laboratory analysis indicates that the contaminant is not present at a detectable level.

Not Applicable (N/A) - Not applicable.

| Contaminant (Unit of Measurement) | Year Tested | Violation Yes/No | Supply Source | Level Detected | Range | MCL in CCR units | MCLG | Major Sources in Drinking Water |
|--------------------------------------|-------------|------------------|---------------|----------------|-------|------------------|------|---------------------------------|
|--------------------------------------|-------------|------------------|---------------|----------------|-------|------------------|------|---------------------------------|

Inorganic Contaminants

| | | | | | | | | |
|----------------|------|----|------|----------|---------------|--------|-----|---|
| Copper (ppm) | 2010 | No | CWSA | 0.42 (a) | 0.11-0.51 (b) | AL=1.3 | 1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| Fluoride (ppm) | 2012 | No | CWSA | 0.35 | (c) | 2 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| Lead (ppb) | 2010 | No | CWSA | 0 (a) | 0-6 (b) | AL=15 | 0 | Corrosion of household plumbing systems; erosion of natural deposits |
| Nitrate (ppm) | 2012 | No | CWSA | 0.77 | (c) | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |

| Contaminant (Unit of Measurement) | Year Tested | Violation Yes/No | Supply Source | Level Detected | Range | MCL in CCR units | MCLG | Major Sources in Drinking Water |
|--------------------------------------|-------------|------------------|---------------|----------------|-------|------------------|------|---------------------------------|
|--------------------------------------|-------------|------------------|---------------|----------------|-------|------------------|------|---------------------------------|

Volatile Organic Contaminants

| | | | | | | | | |
|--------------------------------|------|----|------|-----|-----------|-----|-----|---|
| 1,1,1-Trichloroethane (ppb) | 2012 | No | CWSA | 2.5 | 1.7 – 3.2 | 200 | 200 | Discharge from metal degreasing sites and other factories |
| 1,1-Dichloroethylene (ppb) | 2012 | No | CWSA | 0.7 | 0.6 – 0.9 | 7 | 7 | Discharge from industrial chemical factories |
| Cis-1,2-Dichloroethylene (ppb) | 2012 | No | CWSA | 5.5 | 4.3 – 6.6 | 70 | 70 | Discharge from industrial chemical factories |

Disinfection Byproducts (DBPs), Byproduct Precursors, and Disinfectant Residuals

| | | | | | | | | |
|-------------------------------|------|----|------|------|-------------|----------|----------|---|
| Haloacetic Acids (ppb) | 2012 | No | CWSA | 7.8 | (c) | 60 | N/A | By-product of drinking water disinfection |
| Total trihalomethanes (ppb) | 2012 | No | CWSA | 58 | (c) | 80 | N/A | By-product of drinking water disinfection |
| Chlorine ^(d) (ppm) | 2012 | No | CWSA | 1.19 | 0.02 – 1.78 | MRDL = 4 | MRDLG= 4 | Water additive used to control microbes |

Entry Point Disinfection Residual

| Contaminant (Unit of Measurement) | Year Tested | Violation Yes/No | Minimum Disinfectant Residual Required | Lowest Level Detected | Range of Detections | Major Sources in Drinking Water |
|--------------------------------------|-------------|------------------|--|-----------------------|---------------------|---|
| Chlorine ^(e) (ppm) | 2012 | No | 0.42 | 0.89 | 0.89 – 1.66 | Water additive used to control microbes |

Footnotes:

- (a) 90th Percentile Value
- (b) None of the 20 samples taken exceeded the action level.
- (c) Only one sample required
- (d) The detected level is the highest monthly average chlorine residual in the distribution system.
- (e) The reported values are the lowest daily values leaving the treatment plant

Unregulated Contaminants

We have been voluntarily sampling for unregulated Volatile Organic Compounds. We have found through this testing that MTBE, a gasoline additive, has been found in our source water. Testing results for our drinking water have been between 3.1 to 3.9 PPB with an average being 3.5 PPB. There currently has been no limit set by EPA for this contaminant. However, a level of 20–40 PPB has been recommended as a taste and odor threshold. For more information about MTBE please refer to the EPA website <http://www.epa.gov/mtbe/>. The EPA MTBE factsheet may be obtained by going to the following link <http://www.epa.gov/waterscience/criteria/drinking/mtbefact.pdf> and also is available at the Coraopolis municipal building. We will continue to monitor for MTBE and explore possible options of treatment.

What does this data mean?

As you can see by the table, our system had no water quality violations. We're proud that your drinking water meets Federal and State requirements. However, we have learned through our monitoring and testing that some constituents have been detected and will be diligent in monitoring for these contaminants.

All sources of drinking water are subject to potential contaminants that are naturally occurring or man made. Those contaminants can be microbes, organic or inorganic chemicals, or radioactive materials. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Nationally, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts or industrial process and petroleum production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Information about Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Coraopolis Water & Sewer Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Public Notification

In 2009, CWSA instituted an automated phone dialing system to notify customers of important information about their drinking water. Please be sure that our office has the most up to date information so that we can be sure that you will be contacted in the event of an emergency or for other planned events such as annual flushing of hydrants. We need your help to ensure that this system works. You may also update your contact information by visiting our website.